

WET-NICHE LIGHT

- ① Lights over 15 volts to be on GFCI per 680-20(a)(1)
- ② An unspliced #12 cu. mm. size, insulated equip. grounding conductor inside conduit to the br.ckt. panel. = 680-22(b)

